



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Borrego Water District  
 Contact: Alan Asche  
 Address: 806 Palm Canyon Drive  
 Borrego Springs, CA 92004

Analytical Report: Page 1 of 9  
 Project Name: Borrego WD-DW-no CC  
 Project Number: NMA PFAS Sampling - Borrego  
 Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469

Received on Ice (Y/N): Yes Temp: 3 °C

Attached is the analytical report for the sample(s) received for your project. Below is a list of the individual sample descriptions with the corresponding laboratory number(s). Also, enclosed is a copy of the Chain of Custody document (if received with your sample(s)). Please note any unused portion of the sample(s) may be responsibly discarded after 30 days from the above report date, unless you have requested otherwise.

Thank you for the opportunity to serve your analytical needs. If you have any questions or concerns regarding this report please contact our client service department.

**Sample Identification**

<u>Lab Sample #</u>	<u>Client Sample ID</u>	<u>Matrix</u>	<u>Date Sampled</u>	<u>By</u>	<u>Date Submitted</u>	<u>By</u>
C3H3469-01	ID4 - Well 9 ---SPECIAL--- 034_034	Water	08/24/23 07:05	Alan Asche	08/24/23 10:15	Alan Asche
C3H3469-03	ID4 - Well 11 ---SPECIAL--- 010_010	Water	08/24/23 07:26	Alan Asche	08/24/23 10:15	Alan Asche
C3H3469-05	ID4 - Well 18 ---SPECIAL--- 012_012	Water	08/24/23 07:13	Alan Asche	08/24/23 10:15	Alan Asche



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Borrego Water District  
 Contact: Alan Asche  
 Address: 806 Palm Canyon Drive  
 Borrego Springs, CA 92004

Analytical Report: Page 2 of 9  
 Project Name: Borrego WD-DW-no CC  
 Project Number: NMA PFAS Sampling - Borrego  
 Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469

Received on Ice (Y/N): Yes Temp: 3 °C

Laboratory Reference Number  
**C3H3469-01**

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
ID4 - Well 9 034_034	Water	08/24/23 07:05	08/24/23 10:15

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b>Testing performed by: Babcock Laboratories, Inc. - Riverside</b>							
CA ELAP No. 2698, EPA No. CA00102, NELAP No. OR4035							
Per-/Polyfluorinated Alkyl Substances							
Perfluorobutanoic acid (PFBA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluoropentanoic acid (PFPeA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorohexanoic Acid (PFHxA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluoroheptanoic Acid (PFHpA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorooctanoic Acid (PFOA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorononanoic Acid (PFNA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorodecanoic Acid (PFDA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluoroundecanoic Acid (PFUnA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorododecanoic Acid (PFDoDA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorobutanesulfonic Acid (PFBS)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluoropentanesulfonate (PFPeS)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorohexanesulfonic Acid (PFHxS)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluoroheptanesulfonic acid (PFHpS)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluorooctanesulfonic Acid (PFOS)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
4:2 Fluorotelomer Sulfonate	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
6:2 Fluorotelomer Sulfonate	ND	4.3	ng/L	EPA 533	09/19/23 20:15	MOF	
8:2 Fluorotelomer Sulfonate	ND	4.3	ng/L	EPA 533	09/19/23 20:15	MOF	
Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
4,8-dioxa-3H-perfluorononanoic Acid (ADONA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
9-chlorohexadecafluoro-3-oxanon e-1-sulfonic Acid	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
11-chloroeicosafuoro	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
3oxaundecane-1-sulfonic Acid	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluoro-4-methoxybutanoic acid (PFMBA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Perfluoro-3-methoxypropanoic acid (PFMPA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	

mailing  
 P.O. Box 432  
 Riverside, CA 92502-0432

Babcock Laboratories, Inc. - Riverside  
 6100 Quail Valley Court  
 Riverside, CA 92507-0704

P (951) 653-3351  
 F (951) 653-1662  
[www.babcocklabs.com](http://www.babcocklabs.com)

CA ELAP No. 2698  
 EPA No. CA00102  
 NELAP No. OR4035



# BABCOCK Laboratories, Inc.

The Standard of Excellence for Over 100 Years

Client Name: Borrego Water District  
Contact: Alan Asche  
Address: 806 Palm Canyon Drive  
Borrego Springs, CA 92004

Analytical Report: Page 3 of 9  
Project Name: Borrego WD-DW-no CC

Project Number: NMA PFAS Sampling - Borrego Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469

Received on Ice (Y/N): Yes Temp: 3 °C

### Laboratory Reference Number

## C3H3469-01

Sample Description	Matrix	Sampled Date/Time	Received Date/Time
ID4 - Well 9 034_034	Water	08/24/23 07:05	08/24/23 10:15

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b>Testing performed by: Babcock Laboratories, Inc. - Riverside</b>							
CA ELAP No. 2698, EPA No. CA00102, NELAP No. OR4035							
Per-/Polyfluorinated Alkyl Substances							
Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	ND	1.7	ng/L	EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C9-PFNA-[IDA]	88%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C8-PFOS-[IDA]	100%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C8-PFOA-[IDA]	89%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C7-PFUnA-[IDA]	98%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C6-PFDA-[IDA]	93%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C5-PFPeA-[IDA]	82%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C5-PFHxA-[IDA]	88%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C4-PFHpA-[IDA]	84%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C4-PFBA-[IDA]	79%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C3-PFHxS-[IDA]	86%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C3-PFBS-[IDA]	93%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C2-PFDoA-[IDA]	84%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C2-8:2 FTS-[IDA]	116%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C2-6:2 FTS-[IDA]	114%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C2-4:2 FTS-[IDA]	120%	50-200		EPA 533	09/19/23 20:15	MOF	
Surrogate: 13C3-HFPO-DA-[IDA]	75%	50-200		EPA 533	09/19/23 20:15	MOF	



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Borrego Water District  
 Contact: Alan Asche  
 Address: 806 Palm Canyon Drive  
 Borrego Springs, CA 92004

Analytical Report: Page 4 of 9  
 Project Name: Borrego WD-DW-no CC  
 Project Number: NMA PFAS Sampling - Borrego  
 Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469

Received on Ice (Y/N): Yes Temp: 3 °C

Laboratory Reference Number  
**C3H3469-03**

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
ID4 - Well 11 010_010	Water	08/24/23 07:26	08/24/23 10:15

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b><i>Testing performed by: Babcock Laboratories, Inc. - Riverside</i></b>							
<i>CA ELAP No. 2698, EPA No. CA00102, NELAP No. OR4035</i>							
<b>Per-/Polyfluorinated Alkyl Substances</b>							
Perfluorobutanoic acid (PFBA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluoropentanoic acid (PFPeA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorohexanoic Acid (PFHxA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluoroheptanoic Acid (PFHpA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorooctanoic Acid (PFOA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorononanoic Acid (PFNA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorodecanoic Acid (PFDA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluoroundecanoic Acid (PFUnA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorododecanoic Acid (PFDoDA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorobutanesulfonic Acid (PFBS)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluoropentanesulfonate (PFPeS)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorohexanesulfonic Acid (PFHxS)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluoroheptanesulfonic acid (PFHpS)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluorooctanesulfonic Acid (PFOS)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
4:2 Fluorotelomer Sulfonate	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
6:2 Fluorotelomer Sulfonate	ND	4.4	ng/L	EPA 533	09/19/23 20:52	MOF	
8:2 Fluorotelomer Sulfonate	ND	4.4	ng/L	EPA 533	09/19/23 20:52	MOF	
Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
4,8-dioxa-3H-perfluorononanoic Acid (ADONA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
9-chlorohexadecafluoro-3-oxanon e-1-sulfonic Acid	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
11-chloroeicosafuoro	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
3oxaundecane-1-sulfonic Acid	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluoro-4-methoxybutanoic acid (PFMBA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Perfluoro-3-methoxypropanoic acid (PFMPA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	

*mailing*  
 P.O. Box 432  
 Riverside, CA 92502-0432

*Babcock Laboratories, Inc. - Riverside*  
 6100 Quail Valley Court  
 Riverside, CA 92507-0704

P (951) 653-3351  
 F (951) 653-1662  
[www.babcocklabs.com](http://www.babcocklabs.com)

CA ELAP No. 2698  
 EPA No. CA00102  
 NELAP No. OR4035



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Borrego Water District  
 Contact: Alan Asche  
 Address: 806 Palm Canyon Drive  
 Borrego Springs, CA 92004

Analytical Report: Page 5 of 9  
 Project Name: Borrego WD-DW-no CC  
 Project Number: NMA PFAS Sampling - Borrego  
 Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469

Received on Ice (Y/N): Yes Temp: 3 °C

Laboratory Reference Number

**C3H3469-03**

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
ID4 - Well 11 010_010	Water	08/24/23 07:26	08/24/23 10:15

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b>Testing performed by: Babcock Laboratories, Inc. - Riverside</b>							
CA ELAP No. 2698, EPA No. CA00102, NELAP No. OR4035							
Per-/Polyfluorinated Alkyl Substances							
Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	ND	1.8	ng/L	EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C9-PFNA-[IDA]	88%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C8-PFOS-[IDA]	102%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C8-PFOA-[IDA]	91%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C7-PFUnA-[IDA]	102%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C6-PFDA-[IDA]	95%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C5-PFPeA-[IDA]	90%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C5-PFHxA-[IDA]	93%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C4-PFHpA-[IDA]	89%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C4-PFBA-[IDA]	89%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C3-PFHxS-[IDA]	78%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C3-PFBS-[IDA]	87%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C2-PFDoA-[IDA]	93%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C2-8:2 FTS-[IDA]	120%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C2-6:2-FTS-[IDA]	118%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C2-4:2 FTS-[IDA]	120%	50-200		EPA 533	09/19/23 20:52	MOF	
Surrogate: 13C3-HFPO-DA-[IDA]	84%	50-200		EPA 533	09/19/23 20:52	MOF	



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Borrego Water District  
 Contact: Alan Asche  
 Address: 806 Palm Canyon Drive  
 Borrego Springs, CA 92004

Analytical Report: Page 6 of 9  
 Project Name: Borrego WD-DW-no CC  
 Project Number: NMA PFAS Sampling - Borrego  
 Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469

Received on Ice (Y/N): Yes Temp: 3 °C

Laboratory Reference Number  
**C3H3469-05**

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
ID4 - Well 18 012_012	Water	08/24/23 07:13	08/24/23 10:15

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b>Testing performed by: Babcock Laboratories, Inc. - Riverside</b>							
CA ELAP No. 2698, EPA No. CA00102, NELAP No. OR4035							
<b>Per-/Polyfluorinated Alkyl Substances</b>							
Perfluorobutanoic acid (PFBA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluoropentanoic acid (PFPeA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorohexanoic Acid (PFHxA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluoroheptanoic Acid (PFHpA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorooctanoic Acid (PFOA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorononanoic Acid (PFNA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorodecanoic Acid (PFDA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluoroundecanoic Acid (PFUnA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorododecanoic Acid (PFDoDA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorobutanesulfonic Acid (PFBS)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluoropentanesulfonate (PFPeS)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorohexanesulfonic Acid (PFHxS)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluoroheptanesulfonic acid (PFHpS)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluorooctanesulfonic Acid (PFOS)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
4:2 Fluorotelomer Sulfonate	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
6:2 Fluorotelomer Sulfonate	ND	4.5	ng/L	EPA 533	09/19/23 21:29	MOF	
8:2 Fluorotelomer Sulfonate	ND	4.5	ng/L	EPA 533	09/19/23 21:29	MOF	
Hexafluoropropylene oxide dimer acid (HFPO-DA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
4,8-dioxa-3H-perfluorononanoic Acid (ADONA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
9-chlorohexadecafluoro-3-oxanon e-1-sulfonic Acid	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
11-chloroeicosafuoro	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
3oxaundecane-1-sulfonic Acid	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Nonafluoro-3,6-dioxaheptanoic acid (NFDHA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluoro-4-methoxybutanoic acid (PFMBA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Perfluoro-3-methoxypropanoic acid (PFMPA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	

mailing  
 P.O. Box 432  
 Riverside, CA 92502-0432

Babcock Laboratories, Inc. - Riverside  
 6100 Quail Valley Court  
 Riverside, CA 92507-0704

P (951) 653-3351  
 F (951) 653-1662  
 www.babcocklabs.com

CA ELAP No. 2698  
 EPA No. CA00102  
 NELAP No. OR4035



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Borrego Water District  
 Contact: Alan Asche  
 Address: 806 Palm Canyon Drive  
 Borrego Springs, CA 92004

Analytical Report: Page 7 of 9  
 Project Name: Borrego WD-DW-no CC  
 Project Number: NMA PFAS Sampling - Borrego  
 Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469

Received on Ice (Y/N): Yes Temp: 3 °C

Laboratory Reference Number  
**C3H3469-05**

<u>Sample Description</u>	<u>Matrix</u>	<u>Sampled Date/Time</u>	<u>Received Date/Time</u>
ID4 - Well 18 012_012	Water	08/24/23 07:13	08/24/23 10:15

Analyte(s)	Result	RDL	Units	Method	Analysis Date	Analyst	Flag
<b>Testing performed by: Babcock Laboratories, Inc. - Riverside</b>							
CA ELAP No. 2698, EPA No. CA00102, NELAP No. OR4035							
Per-/Polyfluorinated Alkyl Substances							
Perfluoro(2-ethoxyethane)sulfonic acid (PFEEESA)	ND	1.8	ng/L	EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C9-PFNA-[IDA]	79%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C8-PFOS-[IDA]	94%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C8-PFOA-[IDA]	77%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C7-PFUnA-[IDA]	91%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C6-PFDA-[IDA]	87%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C5-PFPeA-[IDA]	74%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C5-PFHxA-[IDA]	77%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C4-PFHpA-[IDA]	80%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C4-PFBA-[IDA]	75%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C3-PFHxS-[IDA]	77%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C3-PFBS-[IDA]	89%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C2-PFDoA-[IDA]	87%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C2-8:2 FTS-[IDA]	125%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C2-6:2 FTS-[IDA]	130%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C2-4:2 FTS-[IDA]	137%	50-200		EPA 533	09/19/23 21:29	MOF	
Surrogate: 13C3-HFPO-DA-[IDA]	68%	50-200		EPA 533	09/19/23 21:29	MOF	



**BABCOCK Laboratories, Inc.**  
*The Standard of Excellence for Over 100 Years*

Client Name: Borrego Water District  
Contact: Alan Asche  
Address: 806 Palm Canyon Drive  
Borrego Springs, CA 92004

Analytical Report: Page 8 of 9  
Project Name: Borrego WD-DW-no CC  
Project Number: NMA PFAS Sampling - Borrego  
Spr. CA 92004

Report Date: 22-Sep-2023

Work Order Number: C3H3469  
Received on Ice (Y/N): Yes Temp: 3 °C

**Notes and Definitions**

- ND: Analyte NOT DETECTED at or above the Method Detection Limit (if MDL is reported), otherwise at or above the Reportable Detection Limit (RDL)
- NR: Not Reported
- RDL: Reportable Detection Limit
- MDL: Method Detection Limit
- \* / " " : NELAP does not offer accreditation for this analyte/method/matrix combination

**Approval**

Enclosed are the analytical results for the submitted sample(s). Babcock Laboratories certify the data presented as part of this report meet the minimum quality standards in the referenced analytical methods. Any exceptions have been noted.

  
Amanda Christy Porter

cc:

E-SHORT\_NO ALIAS.RPT

This report applies only to the sample(s) analyzed. As a mutual protection to clients, the public, and Babcock Laboratories, Inc., this report is submitted and accepted for the exclusive use of the Client to whom it is addressed. Interpretation and use of the information contained within this report are the sole responsibility of the Client. Babcock Laboratories, Inc. is not responsible for any misinformation or consequences that may result from misinterpretation or improper use of this report. This report is not to be modified or abbreviated in any way. Additionally, this report is not to be used, in whole or in part, in any advertising or publicity matter without written authorization from Babcock Laboratories, Inc. The liability of Babcock Laboratories, Inc. is limited to the actual cost of the requested analyses, unless otherwise agreed upon in writing. There is no other warranty expressed or implied.

mailing  
P.O. Box 432  
Riverside, CA 92502-0432

Babcock Laboratories, Inc. - Riverside  
6100 Quail Valley Court  
Riverside, CA 92507-0704

P (951) 653-3351  
F (951) 653-1662  
www.babcocklabs.com

CA ELAP No. 2698  
EPA No. CA00102  
NELAP No. OR4035





BABCOCK Laboratories, Inc.  
The Standard of Excellence for Over 100 Years

6100 Quail Valley Court Riverside, CA 92507  
(951) 653-3351 • FAX (951) 653-1662  
www.babcocklabs.com

# Chain of Custody & Sample Information Record

Client: Boniego Water District Contact: Alan Asche 760-315-3171 Fax No. 760-767-5994  
 Phone No. 760-767-5806 email: alan@boniegowd.com  
 Project Name: NMA PFAS Sampling Turn Around Time: Routine \*72 Hour Rush \*48 Hour Rush \*24 Hour Rush  
 Project Location: Boniego Spr Ca 92004 \*Lab TAT Approval: By: [Signature] \*Additional Charges Apply (Include Source Number in Notes)

Sampler Information

Name: Alan Asche  
 Employer: BWD  
 Signature: [Signature]

Sample ID	Date	Time	# of Containers & Preservatives							Total # of Containers	Sample Type			Analysis Requested	Matrix	Notes
			Unpreserved	H <sub>2</sub> SO <sub>4</sub>	HCl	HNO <sub>3</sub>	Na <sub>2</sub> S <sub>2</sub> O <sub>3</sub>	NaOH	NaOH/Zn Acetate		NH <sub>4</sub> Cl	PDC	Routine			
ID4-Well 9	8-24-23	7:05am								4				XX		CA3710036-034-034
ID4-Well 11	8-24-23	7:26am								4				XX		CA3710036-010-010
ID4-Well 18	8-24-23	7:13am								4				XX		CA3710036-012-012

Relinquished By (sign)	Print Name / Company	Date / Time	Received By (sign)	Print Name / Company
<u>[Signature]</u>	<u>Alan Asche / BWD</u>	<u>8-24-23 / 10:15</u>	<u>[Signature]</u>	<u>[Signature]</u>

By signing on behalf of your organization and relinquishing this chain of custody you agree to abide by the Babcock Laboratories, Inc. Terms and Conditions.

(For Lab Use Only) Sample Integrity Upon Receipt/Acceptance Criteria

Sample(s) Submitted on Ice?  Yes  No Sample meets laboratory acceptance criteria?  Yes  No  
 Custody Seal(s) Intact?  Yes  No NA Permission to continue:  Yes  No  
 Sample(s) Intact?  Yes  No Deviation/Notes: \_\_\_\_\_  
 Temperature: 3°C  Cooler Blank Signature/Date: \_\_\_\_\_

**C3H3469**  
 Rc'd: 08/24/2023 10:15  
 J1H Spooler